

**Annual Drinking Water Quality Report**  
**Varner Creek Utility District - PWS TX0200070**  
**For the period of January 1 – December 31, 2015**

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. Information about VCUD and a link to the TCEQ website can be found on the District's website at [www.VarnerCreekUtilityDistrict.org](http://www.VarnerCreekUtilityDistrict.org).

For more information regarding this report, contact: Debra Lanehart, District Administrator  
(979) 345-6008

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (\_\_\_\_) \_\_\_\_-\_\_\_\_.

Or attend a regular VCUD Board of Directors meeting: 3<sup>rd</sup> Wednesday of every month at 9:00 a.m.  
Oak Room, Columbia Lakes Clubhouse

**Sources of Drinking Water**

Varner Creek Utility District's water source is Ground Water from the Chicot Aquifer.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791).

## Lead and Copper

Year	Contaminant	The 90 <sup>th</sup> Percentile	Number of Sites Exceeding Action Level	Action Level	Unit of Measure	Source of Contaminant
2014	Lead	3.7	0	15	ppb	Corrosion of household plumbing systems; erosion of natural deposits.
2014	Copper	.15	0	1.3	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## Information about Source Water Assessments

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts in our system, contact the District's Engineer at Baker & Lawson, (979) 849-6681.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL:  
<http://gis3.tceq.state.tx.us/swav/Controller/index.jsp?wtrsrc=>

Further details about sources and source-water assessments are available in Drinking Water Watch at the following URL: [dww2.tceq.texas.gov/DWW/](http://dww2.tceq.texas.gov/DWW/)

Source Water Name	Type of Water	Report Status	Location
1 - 2 LAKESIDE DR	LAKESIDE DR	GW	Chicot Aquifer
2 - 329 WELLSHIRE AVE	WELLSHIRE AVE	GW	Chicot Aquifer

### Chlorine Info

Chemical Used	Avg Level Qtrly Data	Lowest Result of Single Sample	Highest Result of Single Sample	Maximum Residual Disinfectant Level (MRDL)	Maximum Residual Disinfectant Level Goal (MRDLG)	Unit of Measure	Source of Chemical
Chlorine	0.70 mg/L	0.26 mg/L	1.7 mg/L	1.7 mg/L	< 4.0 mg/L	mg/L	AOC (chlorine bottle)

### Regulated Contaminants Detected

#### Coliform Bacteria

Maximum Contaminant	Total Coliform Maximum	Highest No. of Positive	Fecal Coliform or E. Coli Maximum	Total No. of Positive E. Coli or Fecal	Violation	Likely Source of Contamination
0	1 positive monthly sample	1		0	N	Naturally present in the environment

## Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)*	2015	2	2.4-2.4	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2015	20	20.4-20.4	No goal for the total	80	ppb	N	By-product of drinking water disinfection.

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2015	0.255	0.255 - 0.255	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2015	0.57	0.57 - 0.57	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2015	0.01	0.01 - 0.01	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	2015	2.6	2.6-2.6	0	5	pCi/L	N	Erosion of natural deposits.

## Violations Table

<b>Lead and Copper Rule</b>			
The Lead and Copper Rule protects public health by minimizing lead and copper levels in drinking water, primarily by reducing water corrosivity. Lead and copper enter drinking water mainly from corrosion of lead and copper containing plumbing materials.			
<b>Violation Type</b>	<b>Violation Begin</b>	<b>Violation End</b>	<b>Violation Explanation</b>
LEAD CONSUMER NOTICE (LCR)	12/30/2014	3/12/2015	We failed to provide the results of lead tap water monitoring to the consumers at the location the water was tested. These were supposed to be provided no later than 30 days after learning the results. Results were provided immediately upon notification of violation.

### Water Quality Test Results Definitions:

**The included tables contain scientific terms and measures, some of which may require explanation.**

Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MFL	million fibers per liter (a measure of asbestos)
na:	not applicable.
NTU	nephelometric turbidity units (a measure of turbidity)
pCi/L	picocuries per liter (a measure of radioactivity)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
ppt	parts per trillion, or nanograms per liter (ng/L)
ppq	parts per quadrillion, or picograms per liter (pg/L)